



## Gibraltar Maritime Administration

HM Government of Gibraltar

Watergate House  
2/8 Casemates Square  
Gibraltar

Tel (+350)200 46862 / 200 47771 /200 50424  
Fax (+350) 200 47770  
e-mail: [maritime.survey@gibraltar.gov.gi](mailto:maritime.survey@gibraltar.gov.gi)  
[maritime.registry@gibraltar.gov.gi](mailto:maritime.registry@gibraltar.gov.gi)

### Shipping Information Notice – 050 COSMO MED and Type Approved Fire Doors – Faulty A60, A0 and B15 Fire doors

---

To: Ship owners, Operators, Managers, DPA's

---

The United Kingdom Maritime & Coastguard Agency (UK MCA) have been notified of an issue which has arisen with fire doors manufactured by COSMO Co. Ltd.

COSMO Fire doors of A60, A0 and B15 standard that have been type approved and are certified to MED Modules B and D by DNV GL, produced between November 2013 and July 2017 might be affected by this issue.

Owners/operators/managers are requested to follow advice/guidance provided in the UK MCA Safety Bulletin 10 which can be accessed from the UK MCA website:

[https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/641021/Safety\\_Bulletin\\_10\\_Cosmo\\_Fire\\_Doors.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/641021/Safety_Bulletin_10_Cosmo_Fire_Doors.pdf) )

If evidence of these faulty doors is discovered then contact should be made to [maritime.survey@gibraltar.gov.gi](mailto:maritime.survey@gibraltar.gov.gi) and your Classification Society.

Richard Montado  
Maritime Administrator

Issue date: 31 August 2017

All notices are available through [www.gibraltarship.com](http://www.gibraltarship.com)

This copy of the Administrative Instruction has been sent electronically and does not carry a signature or official stamp. A sign and stamped copy will be available upon request